

## Measurement of equivalent sound absorption area

**Test** Measurement of equivalent sound absorption area in a reverberation room according to EN ISO 354  
**Client** Ecophon AB  
 Erling Nilsson  
**Object** Solo Square, Single panel  
 Thickness: 40 mm.  
 Panel size: 1200 mm x 1200 mm.  
**Date of test** February 12-14, 2008  
**Conditions** Mounting depth: 400 mm.  
 Room volume: 200 m<sup>3</sup>.  
 Temperature at measurement on object/in empty room: 19/ 19 °C.  
 Relative humidity at measurement on object/in empty room: 81/ 81 %  
 Measurements were made at 3 different positions in the reverberation room and the reverberation times were averaged.

Equivalent sound absorption area

