


## FOCUS F

## Visual design edge



The ceiling will consist of direct fixed glass fiber ceiling panels Ecophon Focus (edge F). The ceiling has an even appearance, with the beveled edges forming a discreet groove between the tiles. Panels available in format 600x600x20 mm and 1200x600x20 mm. The panels are clicked to each other on one side and then fixed on the other side.

The weight of the system should be approximately 2,5 kg/m<sup>2</sup>. The visible surface of the ceiling tile will be Akutex™ FT, colour White Frost, painted surface with water-based paint. The edges will be painted.

**Installation:** The system should be installed according to Ecophon installation diagram M15. Edges of cut perimeter tiles should be coated with Edge Sealant. The panels are not removable.

**Visual appearance:** The closest NCS colour of the white visible surface of the panels. The ceiling surface will have a light reflectance of 85% and gloss level below 1.

**Acoustic absorption:** The ceiling will be of sound absorption class C, will have a weighted sound absorption coefficient  $\alpha_w$  of 0,75 and octave band practical sound absorption coefficients:

125 Hz	250 Hz	500 Hz	1000 Hz	2000 Hz	4000 Hz
0.10	0.45	0.85	1.00	0.95	1.00

Values will be measured according to EN ISO 354 and classification according to EN ISO 11654.

**Fire safety:** The ceiling tiles will be classified A2-s1, d0 according to EN 13501-1. The glass wool core will be tested and classified as non-combustible according to EN ISO 1182.

**Mechanical Stability:** panels should remain 100% stable in environments reaching up to 95% relative humidity and 30°C temperature. They should be tested according to EN 13964:2014, Annex F.

**Indoor Health and Wellbeing:** Ceilings panels should comply with the French regulation on VOC emissions, A level. They should also be certified by the Finnish Building Information Group (RTS) with the M1 label. The panels should be free from Substances of Very High Concern (SVHC) above 100 ppm as defined by the European REACH regulation (No 1907/2006).

**Circularity:** The minimum post-recycled content of ceiling tiles should be 60%. Tiles should be 100% recyclable.

**CE marking:** The ceiling system should be CE-marked according to the harmonised standard EN 13964:2014 ("Suspended ceilings, requirements and tests methods"), with relevant Declarations of Performance (DoPs) issued.

**Maintenance:** Daily dusting and vacuum cleaning. Weekly wet wiping.