


SUPER G B

Visual design edge



The ceiling should consist of glass fibre ceiling panels Ecophon Super G B with bevelled edges to be directly mounted to the soffit with a glued application, in format 600x600x40 mm. Panels should be glued to the soffit using Connect Absorber Glue.

The weight of the system should be approximately 5 kg/m². The visible surface of the ceiling tile should be Super G, a white painted strong glass fiber fabric. The edges should be painted.

Installation: The system should be installed according to Ecophon installation guides M298. The panels should be glued on a clean and smooth soffit. Edges of cut perimeter tiles should be coated with Edge Sealant. The panels are not removable.

Visual appearance: The closest NCS colour of the white visible surface of the panels should be S 1002-Y. The ceiling surface should have a light reflectance of 78%.

Acoustic absorption: The ceiling should be of sound absorption class A, should have a weighted sound absorption coefficient α_w of 1.00 and octave band practical sound absorption coefficients (overall depth of system: 43 mm) of:

125 Hz	250 Hz	500 Hz	1000 Hz	2000 Hz	4000 Hz
0.25	0.80	1.00	1.00	1.00	1.00

Values should be measured according to EN ISO 354 and classification according to EN ISO 11654.

Fire safety: The ceiling tiles should be classified A2-s1, d0 according to EN 13501-1. The glass wool core should be tested and classified as non-combustible according to EN ISO 1182.

Mechanical Stability: Panels should remain 100% stable in environments reaching up to 95% relative humidity and 30°C temperature. They should be tested according to EN 13964:2014, Annex F.

Impact Resistance: The ceiling should be classified for impact resistance Class 3A according to EN 13964 annex D.

Indoor Health and Wellbeing: Ceilings panels should comply with the French regulation on VOC emissions, A level. They should also be certified by the Finnish Building Information Group (RTS) with the M1 label. The panels should be free from Substances of Very High Concern (SVHC) above 100 ppm as defined by the European REACH regulation (No 1907/2006).

Circularity: The minimum post-recycled content of ceiling tiles should be 61%. Tiles should be 100% recyclable.

CE marking: The ceiling system should be CE-marked according to the harmonised standard EN 13964:2014 ("Suspended ceilings, requirements and tests methods"), with relevant Declarations of Performance (DoPs) issued.

Maintenance: Daily dusting and vacuum cleaning. Weekly wet wiping.